

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:41 pm

PWS ID: UTAH22113 **Name:** WANSHIP WELL WATER SYSTEM
Legal Contact: WANSHIP WELL WATER SYS. **Rating:** Approved
TAGE FLINT **Rating Date:** 04/09/1996
Address: 2837 E HWY 193 **Activity Status:** Active
LAYTON, UT 84041
Phone Number: 435-359-4494
City Served (Area):
County: SUMMIT COUNTY
System Type: Non-community **Last Inv Update:** 01/19/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/20/2010 **Total Dsgn Cap:**
Population: 100 **Surveyor:** NATHAN TODD LUNST **Total Emerg Cap:**
Oper Period: 6/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	FLINT, TAGE	MANAGER	801-359-4494		TFLINT@WEBERBASIN.CC

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	2
			2 Total Svc Connections

Storage

Total Storage: 2,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	2,000 GAL	Steel		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WANSHIP WELL CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WANSHIP WELL	Active	WL	80	150 GPM	30 GPM	Yes	GW	Permanent	6/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.